



**The City of Eagle Pass
Fire Marshal's Office
2558 El Indio Hwy
Eagle Pass, Texas 78852
Phone (830)773-1915
Fax (830)757-9152
ecuevas@eaglepasstx.us**

Flammable/Combustible Liquid Tank Plan Submittal Requirements

Flammable/Combustible liquid tanks, installed in the City of Eagle Pass shall meet all the requirements of the 2015 International Fire Code, local amendments, as well as all applicable NFPA standards. All final systems testing and inspections will be witnessed by the Eagle Pass Fire Marshal's Office. The following is a check list of information that should be used as an aid and is not intended to cover every code requirement.

Permit Application

Copy of License current issued by The State of Texas Fire Marshal

System designer
Contractor/Company
Installers

Submittal Packet

System Design Description
Manufacturer's Product Information Sheets of Listed Devices
Specifications for piping
List of materials

Scaled Plans (1/8" minimum scale) 1 PDF copy

Legend
North Arrow
Site plan with accurate dimensions
Distances from property lines and all adjacent structures on and off site
Location of emergency shut off
Location of extinguisher
System designers stamp with wet signature

Modification permit

Permit application
Copy of licenses
Plans 1/8" scale, 2 copies, stamped and wet signed
Legend showing existing, relocated or additional equipment
cut sheets for each new device or piece of equipment

Required inspections

Emergency shut off
Low pressure hydro
Underground visual

Tank Removal

Copy of license

Scope of work

Inspector onsite during pull

Plan review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. System acceptance inspections are required and should be called in at least 24 hours prior to requested inspection times. A re-inspection fee of \$15 will be assessed on systems that are not in complete compliance with all applicable codes. All devices will be tested in an approved manner. Installation/modification permit and an approved set of plans shall remain at the job site and provided to inspectors when requested.